

Hardware Installation Guide Update: Cable Cross Reference Table

Last Modified on 12/21/2021 11:07 am EST

Product Name

Hardware Installation Guide Update: Cable Cross Reference Table

General Information

The Cable Cross Reference Table below supersedes that listed in the *Hardware Installation Guide*.

Purpose	Cable type	Gauge	Cond.	Description	Belden number	Tappan number	General Cable number	West Penn number
RS-485, 2-wire	Non-plenum	24	1P	Overall shield	9841	L19827	C0841A	D4851
RS-485, 2-wire	Plenum	24	1P	Overall shield	82841, 89841	M19899, T19984	n/a, C8117	n/a n/a
RS-485, 4-wire	Non-plenum	24	2P	Overall shield	9842	L19954	C0842A	D4852
RS-485, 4-wire	Plenum	24	2P	Overall shield	88102	K19970	C8118	n/a
RS-232	Non-plenum	24	5	Overall shield	9610	A10043	C0953A	n/a
	Plenum	24	6	Overall shield	83506	T10001	n/a	n/a
Reader	Non-plenum	24	2P	Overall shield	9502	R19756	C0601A	n/a
	Non-			Overall	5504FE,	R20076,	E2006S,	3270,

drops	plenum	22/24	6	shield	9536	R10024	C0743A	n/a
Purpose	Cable	Gauge	Cond.	Description	Belden	Tappan	General Cable	West Penn
	type				number	number	number	number
	Plenum	22/24	6	Overall shield	6504FE	P20019	E2106S	253270B
12 VDC power	Non-plenum	18	2	Overall shield	5300FE, 8760	R40013, L40008	E2032S, C2534A	293, 77293
	Plenum	18	2	Overall shield	6300FE, 88760	P40133, T40030	E2202S, C8101	25293B

Applies To

OnGuard 2010 (6.4.500) or later

Additional Information

None