

# How enable Alarm Name for Access Granted/Access Denied for Destination Floors.

Last Modified on 06/06/2025 3:34 pm EDT

How to enable Alarm Name for Access Granted/Access Denied for Destination Floors

## Procedure Steps

1. From **System Administration** open [Monitoring] and select [Alarms].
2. Find the alarm titled, **Access Granted to Destination Floor**.
3. Identify the current selection for **Alarm description Format**. Refer to example below.

The screenshot shows the 'Alarm Configuration' window for the 'Access Granted to Destination Floor' alarm. The 'Alarm description format' is currently set to 'Event Text Only'. The 'Assigned event(s)' table shows the event 'Access Granted to Destination Floor' with device '\_Default\_', type '\_Default\_', and parameter 'None'.

Alarm	Type	Priority
Access Door Status Monitor Trouble	System	100
Access Exit Request Trouble	System	100
Access Granted	System	50
Access Granted Entry Made	System	50
Access Granted to Destination Floor	System	50
Access Granted: Reader Unlocked	System	50
Access Level Change	System	100
Access Lockout	System	150
Access Open	System	100
Access Point Bypass	System	100
Access Program Exit	System	100
Access Relay/Trigger Fail	System	100
Access Request to Exit Shunt	System	100
Access Schedule Change	System	100
Access Trouble	System	150

Link Summary

Name: Access Granted to Destination Floor Priority: 50

☒ Display alarm ☐ Must mark in progress  
☒ Print alarm ☒ Must acknowledge  
☐ Visual notification ☐ Require login on acknowledge  
☐ Display map ☐ Must enter response on acknowledge  
☐ Video verification ☐ Don't delete on acknowledge  
☐ Show cardholder ☐ Operator can change response  
☐ Active alarm  
☐ Aggregate alarm

Alarm description format: Event Text Only

Assigned event(s):

Event	Device	Type	Parameter
Access Granted to Destination Floor	_Default_	_Default_	None

4. Select [Alarm Name Only] if it is not already selected.

The screenshot shows the 'Alarm Configuration' window for the 'Access Granted to Destination Floor' alarm. The 'Alarm description format' is now set to 'Alarm Name Only'. The 'Assigned event(s)' table shows the event 'Access Granted to Destination Floor' with device '\_Default\_', type '\_Default\_', and parameter 'None'.

Device: 0 of 32 selected

Device	Type
_Default_	_Default_
131.Door Contact	Door Conta
132.Door Contact	Door Conta
3300 1300e.Door Contact	Door Conta
Schlage NDE CM Lock 1.Door Contact	Door Conta

Event:

Event	Type
24 Hour Alarm	Trouble
24 Hour Alarm Restore	Trouble
24 Hour Auto Test	Trouble
24 Hour Non-Burglary Alarm	Trouble
24 Hour Non-Burglary Alarm ...	Trouble
24 Hour Report Closed	Trouble
24 Hour Report Open	Trouble

Name: Access Granted to Destination Floor Priority: 50

☒ Display alarm ☐ Must mark in progress  
☒ Print alarm ☒ Must acknowledge  
☐ Visual notification ☐ Require login on acknowledge  
☐ Display map ☐ Must enter response on acknowledge  
☐ Video verification ☐ Don't delete on acknowledge  
☐ Show cardholder ☐ Operator can change response  
☐ Active alarm  
☐ Aggregate alarm

Alarm description format: Alarm Name Only

Assigned event(s):

Event	Device	Type	Parameter
Access Granted to Destination Floor	_Default_	_Default_	None

5. Save the Alarm Configuration.
6. Restart **Alarm Monitoring**. The display of the alarms will change.

# Applies To

OnGuard (All versions)

## Additional Information

These following alarms will display the floor number only in Alarm Monitoring

Granted Access	12:09 PM 8/29/2017	888 1st Fl Security Cluster	888-02-10 Turnstile Lane 2	None	ADAM WISSE (171151)	050
Granted Access	12:09 PM 8/29/2017	111 Panel # 03 Basement	111-03-10 Turnstile 4 North	None	LORNE MCCOUGALL (82957)	050
Door Forced Open Restore	12:09 PM 8/29/2017	M5 # 72 101 14th Fl Mech Rm	72-02-01 101 Floor 25 West Stairwell Door	None		100
Granted Access	12:09 PM 8/29/2017	101 Panel # 07 Mezz Turnstile	07-01-02 101 Turnstile # 2	None	Matthew Saleys (1054724)	050
Granted Access	12:09 PM 8/29/2017	111 Panel # 06 36th Fl Fan Room	122-02-02 111 36th Fl Freight Lobby	None	Ken Ramsey (155462)	050
35, 1	12:09 PM 8/29/2017	111 02 Elevator Ctrl Mid Rise	111 DEC 12th Floor West Mid Rise	Floor 35, Front Door	ALEXANDER RIKLIN (121083)	050
Granted Access	12:09 PM 8/29/2017	111 Panel # 03 Basement	111-03-00 12th Fl Elevator Mid R2 West	None	ALEXANDER RIKLIN (121083)	050
Granted Access	12:09 PM 8/29/2017	101 Panel # 07 Mezz Turnstile	07-01-02 101 Turnstile # 2	None	Dasha Mikhailova (1053043)	050
35, 1	12:08 PM 8/29/2017	111 01 Elevator Ctrl Low Rise	1 111 DEC 1st Fl Lobby Wall North Low Rise	Floor 5, Front Door	Ken Vislader (162010)	050
Granted Access	12:08 PM 8/29/2017	111 Panel # 04 Basement	111-04-00 1st Fl Lobby Side W/M Low R2 North	None	Ken Vislader (162010)	050
Granted Access	12:08 PM 8/29/2017	101 Panel # 07 Mezz Turnstile	07-01-02 101 Turnstile # 2	None	Arson Dorsey (1053753)	050
Granted Access	12:08 PM 8/29/2017	101 Panel # 07 Mezz Turnstile	07-01-01 101 Turnstile # 1	None	Jane Madena (1053082)	050