

In OnGuard Monitor, still receiving alarms from all devices, even if the device is not part of the same monitor zone

Last Modified on 02/04/2022 5:25 pm EST

Symptom

In OnGuard Monitor, user receives alarms from all available devices even if there are no devices assigned to the chosen monitor zone.

Resolution

Update the OnGuard Monitor module to version 1.2.187 or later.

Applies To

OnGuard Monitor 1.0.117 (base version for OnGuard 7.4), OnGuard Monitor 1.1.126 (base version for OnGuard 7.5).

Additional Information

Copyright © 2022 Carrier. All rights reserved.
