

# Error: The maximum card format ID allowed by access panels has been exceeded

Last Modified on 06/05/2025 6:01 pm EDT

## Symptom

When adding a new card format to an individual segment, OnGuard checks for the next available spot in <All Segments>. If a spot is available, the new card is assigned to that spot. If the first eight spots are taken between <All Segments> and the individual segments, then this error is shown.

## Resolution

Create the new card format separately in each segment.

## Applies To

All OnGuard versions

## Additional Information

System limitation only allows eight <all segment> card formats.

© 2024 Honeywell International Inc. All Rights Reserved.

---